

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		1. CONTRACT ID CODE		PAGE OF PAGES 1 2	
2. AMENDMENT/MODIFICATION NO. 03		3. EFFECTIVE DATE 06/13/2007		4. REQUISITION/PURCHASE REQ. NO.	
5. PROJECT NO. (If applicable)		6. ISSUED BY CODE JSC		7. ADMINISTERED BY (If other than Item 6) CODE JSC	
NASA/Johnson Space Center Attn: BJ3/Elijah Williams 2101 NASA Parkway Houston TX 77058-3696		NASA/Johnson Space Center Attn: BJ3/Elijah Williams 2101 NASA Parkway Houston TX 77058-3696			
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		(x) 9A. AMENDMENT OF SOLICITATION NO. NNJ07182243R			
		x 9B. DATED (SEE ITEM 11) 05/15/2007			
		10A. MODIFICATION OF CONTRACT/ORDER NO.			
		10B. DATED (SEE ITEM 11)			
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended. ☒ is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not. ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

INCO TERMS 2: Destination

See Page 2.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Karen D. Adams	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED 6-13-07

The purpose of Amendment 03 is to:

1. Provide an official answer to an additional question submitted by an Offeror in response to Request for Proposal (RFP) NNJ07182243R.

Question 54: A mechanical contractor that is working with me on this project needs to know who installed the existing Honeywell controls for the HVAC system in bldg 265. He is concerned about the compatibility with the existing controls and the new. If he can't contact the people who installed the system in the existing building, then he won't be able to have the questions he has answered.

Response 54: The HVAC controls on the existing Building 265 stands alone and does not interface with the Honeywell controls as part of the site Energy Management and Control System (EMCS). The Building 265 Addition HVAC controls will function independently of the existing Building 265 or the site EMCS; therefore, the mechanical subcontractor will not need to contact system installers for the existing facility.

Please refer to Changes to Specifications below.

2. Amend RFP NNJ07182243R as follows:
 - a) Incorporate Changes to Specifications as follows:
 1. **15970** - Part I, 1.1: Add the following as the first sentence to the third paragraph: "The Building 265 Addition controls shall have an Ethernet interface that allows connections by others to the JSC site Energy Management and Control System (EMCS) so that no direct interface with the existing Building 265 controls or the JSC site EMCS is required through direct In/Out connections."